

Roger Williams University

DOCS@RWU

Engineering, Computing & Construction
Management Faculty Publications

Engineering, Computing and Construction

2021

My Private Lead Service Line Replacement

Lillian C. Jeznach

Joseph E. Goodwill

Follow this and additional works at: https://docs.rwu.edu/seccm_fp



Part of the [Civil and Environmental Engineering Commons](#)

1

My Private Lead Service Line Replacement

2

Lillian C. Jeznach and Joseph E. Goodwill

3

Accepted for publication in the Journal of the American Water Works Association (JAWWA)

4 **3 Key Takeaways:**

- 5 1. A homeowner’s decision to replace their lead service line can be confounded by factors
6 including their understanding of the science, their perceptions of their lead exposure
7 risks, and the cost of the work.
- 8 2. First draw and 5-minute flush samples may not capture the peak lead concentration,
9 further confounding a customer’s replacement decision.
- 10 3. In my case, lead service line replacement significantly lowered lead concentrations after
11 stagnation based on sequential sampling.

12

13 The science around lead service line (LSL) replacement and drinking water quality is important
14 to water professionals, but they are also topics of concern, and often confusion, for private
15 homeowners may have to weigh the documented risks of lead exposure in the context of their
16 own lives (e.g. what is the age of the house? Are there pregnant women or children at home?)
17 against potentially expensive, even cost prohibitive replacement options.

18 My unique position as both an environmental engineer, professor, and a homeowner with an LSL
19 made me well aware of the documented risks of lead in the literature, but even with my informed
20 perspective, I found the decision to replace was not so straightforward given the information
21 from my local utility’s free lead sampling program, weighing the replacement costs, and the
22 other impacts the replacement might have on my property. So together with a colleague, one of
23 my undergraduate students, and my husband (who is also an engineer by training and willing to
24 go along with my experiment) we decided to capture a homeowner’s decision-making process
25 based on our scientific backgrounds and engineering judgement. Our experience may be helpful

26 in communicating the potential benefits of a full lead service line replacement to homeowners
27 who must start the process of replacing a private LSL.

28

29 **LEAD AND MY HOME**


30 Lead in drinking water originating from LSLs and other premise plumbing is a serious public
31 health concern, particularly for its effects on the cognitive development of children. LSLs are the
32 largest source of lead in drinking water when they are present in public systems. Most countries
33 have banned the use of new lead pipes in drinking water distribution systems, but there are
34 legacy lead pipes in many drinking water systems throughout the industrialized world including
35 the US. Because lead is a toxic metal and harmful to humans, particularly pregnant women and
36 children, at very low exposure levels, the maximum contaminant level goal set by the United
37 States Environmental Protection Agency (USEPA) for lead in drinking water is zero.

38 USEPA sets action levels for lead and copper sampled at the consumer's tap after 6 hours
39 stagnation, and if lead concentrations exceed 15 ppb or copper concentrations exceed 1.3 ppm in
40 more than 10% of customer taps sampled, the system must take additional actions to control
41 corrosion, e.g., additional water quality parameter monitoring, source water
42 monitoring/treatment, corrosion control, and public education (USEPA, 1991). One action that a
43 utility might take is to fully replace or partially replace lead service lines within their distribution
44 network.

45 Replacing LSLs can be confounded by ownership differences across the length of pipe
46 depending on local ordinances, right-of-ways, and property history. It is common for LSLs to

47 have a portion under ownership of the water provider, often from the curb to the water meter,
48 with the rest of the pipeline belonging to the homeowner. A full LSL replacement replaces the
49 entire line, both public and private sections, from the utility-owned water main to the private
50 residence. Full replacement is considered the best option since it completely removes any lead
51 pipe that could contact the potable supply (assuming the household plumbing is lead free).
52 However, replacing a service line is costly and requires homeowner consent and cooperation. In
53 many cases, public water utilities pay to replace the public system's portion of the water
54 distribution system while the homeowners choose to replace the private service line to their
55 homes (i.e., full LSL replacement), or they may decide they cannot or won't, keeping some lead
56 pipe in their plumbing network (i.e., partial LSL replacement).

57 My home is a 1920's American Foursquare (four bedroom, 1.5 bath – see Figure 1) located just
58 outside of Providence, Rhode Island. The home had a partial lead line at the time I bought it in
59 the Summer of 2017, and in my case, the utility owned public main under the street had also
60 been recently replaced. The length of the LSL from the curb stop to the basement is
61 approximately 40 ft. Taking the age of the home into consideration, interior plumbing appears to
62 be a mixture of copper and possibly brass. It is likely that lead solder was used in some areas of
63 the interior plumbing system, although this was not thoroughly examined or confirmed because
64 of some of the premise plumbing is not immediately accessible.



65

66

Figure 1: Home plumbing schematic

67 Our drinking water is provided by Providence Water (PW), which draws water from the Situate
 68 Reservoir in Rhode Island. The reservoir has low pH, alkalinity, and turbidity, and it has
 69 seasonal turnovers as typical for water bodies in the northeastern US. Raw water is treated
 70 conventionally with aeration, coagulation-flocculation, sedimentation, filtration, and disinfection.
 71 Additionally, the water receives fluoride as well as lime addition, and the pH is adjusted for
 72 corrosion control through the distribution system. A small portion of the PW system also
 73 receives orthophosphates as a pilot program for improved corrosion control.

74 PW has tracked recent elevated levels of lead in some homes and buildings within their
 75 distribution network that violate USEPA's Lead and Copper Rule. In 2018, PW's 90th percentile
 76 level was 22 ppb, which is above the lead action limit of 15 ppb. PW has responded by investing
 77 45 million dollars to replace LSLs, and it has made changes to its treatment process to improve

78 corrosion control including maintaining a high pH (~10) in the distribution system and piloting
79 orthophosphate as a corrosion inhibitor.

80 PW is also increased rehabilitating water mains, improved flushing programs, and expanding
81 public education about lead in drinking water. Besides mailing informational pamphlets, PW also
82 provides a “lead service location map” on their website (www.provwater.com) where
83 homeowners can identify if they currently have a utility-owned public lead service line. PW also
84 offers lead testing kits free of charge to its customers; for those testing PW water in their homes,
85 free kits are picked up and dropped off at their Providence office. If a homeowner has a privately
86 owned lead service line, PW has incentivized replacement of the old line with a 0% interest 10-
87 year loan program – this decreases the upfront expense of the replacement cost, roughly \$3,500,
88 as noted in flyers mailed to homeowner customers of PW in the spring of 2020.

89 **APPROACHING THE DECISION AS A SCIENTIST AND HOMEOWNER**

90 Even though I am well informed about the risks of lead exposure from LSLs from my
91 professional experience, I found my questions as a homeowner, specifically the options and their
92 costs, delayed my decision to replace the line. Together with my husband, we tried to assess the
93 various ways we could be exposed to lead in our home. Typically, we only drank water from the
94 refrigerator equipped with a filter (NSF 53 certified to remove lead), and we are both healthy
95 adults. However, I was pregnant and that put me in the at-risk category, since lead
96 bioaccumulates and can be transferred from the mother’s bones to the fetus, possibly affecting
97 fetus brain development.

98 As parents-to-be, we were interested in minimizing exposure from the potential sources of lead
99 in our home, such as lead-based paint, solder in plumbing, and fixtures. Lead solder from

100 premise plumbing can contribute lead to water, and given the age of the house, we likely had this
101 throughout our system. There is also lead paint inside and outside of the house, but a lead paint
102 inspector encapsulated any chipping lead paint throughout, so we considered the risk of lead
103 exposure via paint to be low after these minor fixes were made.

104 Our second consideration was the cost to replace our LSL, i.e., could we afford it with other
105 expenses? Should we get a loan? At the time of the replacement, Providence water was offering
106 a 0% 3-year loan at the time to replace the private side of the LSL. The utility now offers a 10-
107 year 0% interest loan. How does the cost of replacement compare to purchasing filters and only
108 drinking filtered water? We estimated based on the cost of a typical (Brita) filter, average
109 household water consumption, and the life of a filter that after 20 years the cumulative cost of the
110 filter would be greater than the LSL replacement, assuming the LSL replacement is \$5,000.

111 When we asked a realtor about whether or not this investment would increase the value of our
112 home, he thought that it might, but it certainly would not decrease the value. Therefore, if we just
113 considered the costs of the replacement, replacing the LSL would makes sense if we planned on
114 being in our home for a long time (20 years) but using a Brita type filter if we planned on only
115 living there for a few years. Of course, committing to using a filter for drinking water would
116 require that we remember to keep up with filter replacements in order to effectively remove the
117 lead from the water.

118 Our other considerations were mostly cosmetic concerns, but they are valid issues to keep in
119 mind as they will likely be important to most homeowners. The sidewalk in front of the house by
120 the curbstop would be excavated and would need to be replaced at our expense by a contractor.
121 Our lawn would need to be excavated (much to my husband's disappointment), and we were told

122 that excavation could increase up to our porch if the line could not be pulled out of the soil from
123 a distance. If they needed to excavate under the porch then it would require further work by a
124 contractor to fix at our expense. The sprinkler system would also need repairs after the
125 replacement as the excavation would likely go through the sprinkler line.

126 As an engineer, I suspected that the greatest risk of exposure to lead was likely the service line to
127 the home. Even though our home's premise plumbing likely has lead solder, I assumed that the
128 40 ft long LSL was the largest potential source of lead based on surface area exposure if water
129 lay stagnant during periods of no use. The LSL also takes the most time to flush given its
130 distance from the tap. Additionally, if water quality from the utility were to change and lead were
131 inadvertently released from the LSL as a result of changing water conditions at the treatment
132 plant, we would be at a greater risk. I decided that collecting some data on my current lead
133 concentrations after periods of stagnation would increase my confidence in my hypothesis that
134 the LSL posed a risk to lead exposure in our home. Additionally, Providence, RI, has prior
135 violations of the LCR and so further collection of data from a typical older home in the area
136 before and after a LSL replacement would make an interesting case study.

137 Many water utilities offer various forms of lead testing for their customers, some free and some
138 at a cost. I followed the directions on the home test kit that I picked up for free from PW, then
139 sampled from my kitchen sink after an 8-hour stagnation in two 0.5 L sample bottles. This
140 scenario is inherently conservative since it mimics typical overnight minimal water use
141 conditions and increases the opportunity for higher lead levels at the location where someone
142 living in the home may consume water following the stagnation. No other water was running at
143 the time of the sample collection. I collected a first draw sample and a 5-minute flush sample,

144 which represented the water quality after approximately 17 L of water were flushed from the
145 plumbing. The next day I returned the samples to PW and waited for the analysis.

146 The first sample collected from the first draw of 0.5 L of water from the faucet after stagnation
147 contained 4.5 ppb of lead while the the sample collected after 5 minutes of flushing contained 3.1
148 ppb of lead. Both results were less than the lead action level, and if I didn't have some
149 background on the science of lead, I might have thought that although I have a LSL, there was
150 little risk from these low lead levels.

151 What if the results from my lead test were compared to sequential sampling of lead after
152 stagnation – would I feel more confident making the decision to replace my LSL? I was able to
153 determine how many liters of water to collect in order to draw water that has been stagnated in
154 the service line based on measuring temperature changes in the water prior to the sampling
155 effort. The hot water tank in my basement is directly next to the service line entrance to the
156 basement. When I turn on the hot water after things have sat overnight, it takes approximately 4L
157 of water running through the pipes before it becomes increasingly warmer, indicating water
158 originating from the hot water tank had reached the tap (see Figure 2). Based on this information,
159 I determined that 15 sequential samples from the kitchen faucet (two 250 mL and thirteen 1 L
160 samples) were required to analyze for lead. I assumed samples prior to 4 L originated from the
161 house plumbing and samples after 4 L originated from the lead service line outside the house.




Figure 2: Preliminary Water Temperature Sampling

162

163

164

165

166

167

168

169

170

171

172

173

174

175

176

After an 8 hour stagnation period, sequential samples were collected and each were analyzed for temperature, conductivity, pH, and free chlorine by myself, with assistance by my colleague Joseph Goodwill (Assistant Professor of Civil and Environmental Engineering at the University of Rhode Island), and my undergraduate student, Ashley Bosse. It was a hot day in August when the samples were drawn and we noted a temperature change after 4 L of water were sampled, presumably when cooler water was withdrawn from the service line in the ground. Conductivity was within the expected range for treated surface water and it didn't change significantly with cumulative volume. Free chlorine increased with increasing cumulative volume collected, which is expected since chlorine residual decays as water ages. Finally, pH was also consistent with cumulative sampled volume; PW maintains a high pH (around 10) in the distribution system as part of its lead corrosion control strategy.

The samples were analyzed for lead, copper, and iron using ICP-MS. Average copper and iron concentrations were 1.68 ppb (standard deviation of 0.68 ppb) and 53.8 ppb (standard deviation

177 of 2.5 ppb), respectively. The copper concentration was well below the action level of 1.3 ppm.
178 In general, there was no significant change in copper or iron concentrations between sequential
179 samples.

180 Lead concentrations averaged 11.8 ppb (standard deviation of 7.2 ppb) and a slug of higher lead
181 concentrations were withdrawn from the faucet between 3.5 L and 7.5 L with a maximum
182 concentration of approximately 30 ppb measured at the cumulative withdrawal volume of 5.5 L –
183 note, this is twice the lead action level of 15 ppb. Based on when the water changed temperature,
184 the spike in lead levels measured between these cumulative collected volumes is consistent with
185 our previous estimate of water originating from pipes from outside the house after 4 L were
186 drawn. After 7.5 L of water were drawn, the lead concentration decreased to approximately 9
187 ppb.

188 Based on the results of sequential sampling, I felt more confident in spending money to replace
189 my lead service line. The data supported that the lead was coming from the service line, so
190 replacing this service line should minimize the risk of exposure after stagnation periods and in
191 the event there was an inadvertent change in finished water quality from the utility, like lower
192 pH, that could easily result in more pipe corrosion and lead release.

193 **THE REPLACEMENT**

194 In August of 2018, a local contractor, in collaboration with PW and the city, replaced my LSL.
195 Work was carried out over a course of one day following standard service line replacement
196 protocols. After water service was shut off at the curb stop, the LSL was disconnected in the
197 basement at the water meter, and two concrete pads of the sidewalk were excavated. An attempt

198 was made to remove the LSL by pulling it out from the excavated sidewalk area; unfortunately,
199 this didn't work, so approximately 20 ft the front lawn had to be excavated.

200 The LSL was 3/8 inches in diameter and replaced by a 1-inch type k copper pipe. Following
201 replacement and reconnection, the excavation of the front lawn was backfilled. Water was
202 flushed through all household plumbing by the contractor in accordance with replacement
203 guidelines as follows. Outdoor spigots were opened completely and flushed for 15 minutes.
204 Indoor fixtures (with aerators removed) were flushed with cold water beginning on the first floor
205 and ending on the second floor for 30 minutes each.




206
207 Figure 3: A comparison of old and new service lines (A); old lead line (B) and the new
208 copper line (C)

209 Several months after the replacement, I collected more sequential samples after an 8-hour
210 stagnation period from my kitchen sink tap as a comparison with pre-replacement water quality
211 using the same sampling methods. No significant differences in temperature, pH, specific
212 conductivity, or free chlorine before and after the replacement of the service line were found.
213 Average iron and copper concentrations increased slightly after the replacement, as shown in

214 Figure 4. The average iron concentration was 60.2 ppb (standard deviation of 4.9 ppb) and the
215 average copper concentration was 2.59 ppb (standard deviation of 1.67 ppb).

216 The most notable difference in metals concentrations were the lead concentrations before and
217 after service line replacement (Figure 4). After replacement, the average lead concentration was
218 1.8 ppb (standard deviation of 0.3 ppb), which was over 6.5 times smaller than the pre-
219 replacement average of 11.8 ppb, and well below the action level. Concentrations of lead also did
220 not significantly change with sequential samples. With these results in hand, I felt good with the
221 decision to replace my LSL.



222

223

Figure 4: Metal concentrations before and after LSL replacement

224 **WHAT I LEARNED**

225 A homeowner’s decision to replace their lead service line can be confounded by many factors,
 226 including an understanding of the science of lead in drinking water, the relative importance of
 227 different exposure risks to lead in the home, the physical replacement procedure, and the costs. I
 228 made my decision to replace my LSL from a uniquely informed perspective, however, most

229 customers don't have this advantage or investigative resources. I hope that my experience helps
230 utilities better relate to homeowners and communicate information they find helpful.

231 Over the last several years, PW has increased outreach on LSL replacements, yet many of my
232 neighbors have chosen not to have theirs replaced. This is evident on the PW lead service online
233 LSL locator, where of the 35 houses on my street, most built before 1940, only 9 have
234 "suspected of confirmed non-lead or other material", indicating they have likely replaced their
235 original LSL. The other houses in my area have "suspected or confirmed lead" according to the
236 public records available online. This highlights the need for more and better communication by
237 utilities to homeowners about the risks of lead exposure and any financial incentives they offer to
238 ease the financial burden of replacement.

239 Although free lead tests are offered by the PW to homeowners, these can underestimate lead
240 exposure from drinking water based on the results of my own case study. The lead
241 concentrations in Figure 4 clearly illustrate this, where the red asterisks represent the test kit
242 samples below the lead action level. Risk of lead exposure can be masked depending on the
243 sampling procedure if the elapsed volume at the time of the sample does not contain high
244 concentrations of lead. This result may be confusing and misleading to customers who are trying
245 to assess the risks of lead exposure from their water and do not understand why concentrations
246 may vary.

247 Withdrawing sequential volumes of samples from the faucet in this case fully captured the water
248 quality changes at the faucet after stagnation, helping to characterize the exposure patterns of
249 peak lead levels. It was evident from our sequential sampling approach that the highest

250 concentrations of lead occurred between 3 and 7 L of sequential volumes for this particular
251 home.

252

253 Before my LSL was replaced, lead concentrations exceeded the lead action level of 15 ppb,
254 which, while not a violation, represents higher lead exposure risk. Sample methods that include
255 only first draw and 5 minute flush samples (approximately 17 L of cumulative volumes for this
256 home) did not capture the spike of lead at the faucet and therefore did not indicate an exposure
257 risk. This sampling method could allow a utility to meet SDWA requirements, even if consumers
258 are exposed to periodic elevated lead levels once a day or more. However, comparing results
259 from sequential sampling to the first draw and 5-minute flush method confirms that the utility's
260 advice to consumers is useful, namely, that flushing water for 5 minutes decreases the risk of
261 lead exposure (Providence Water). However, it falls to the consumer to remember the 5-minute
262 flush protocol after stagnation, which can be hard to remember and/or cumbersome for some
263 consumers or difficult to follow for small children.

264 My story highlights the water quality benefits of complete LSL replacements to homes where
265 legacy LSLs have already been partially replaced by the water utility. The most significant water
266 quality benefit after the LSL replacement was the decrease in lead concentrations after a period
267 of stagnation to a maximum concentration of only 1.8 ppb. Although there is still a small amount
268 of lead in the drinking water in this home, likely due to lead solder in the original interior
269 plumbing, the risk of higher lead concentrations occurring at my tap was greatly reduced by
270 removing my LSL. I have peace of mind knowing that the lead levels at the taps in my house will
271 be low, and I don't need to remember to flush out my plumbing after stagnation. I hope my

272 example helps utilities better communicate with local homeowners about the risks of lead service
273 lines and the benefits of replacing them.

274 **ACKNOWLEDGEMENTS**

275 I would like to thank Chris Jeznach and Wystan Carswell for their assistance in the data
276 collection before and after the LSL replacement. I would also like to thank my undergraduate
277 student assistant, Ashley Bosse, for her help analyzing samples. Findings presented in this paper
278 do not represent the official views of Providence Water.

279 **REFERENCES**

280 Lead and Drinking Water: Providence Water. Retrieved from <http://www.provwater.com/lead>.

281 Accessed May 26, 2020

282 U.S.EPA (1991). Maximum contaminant level goals and national primary drinking water
283 regulations for lead and copper. Final rule. Federal Register 56, 26460.